

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **SDSU Laboratory Preschool**

City: **Brookings**

Provider Number: **011515520**

Inspector: **Charles Schmidt**

Date of Inspection: **03/07/2024**

Time of Inspection: **9:46 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

17. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05; 61:15:06:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

Multiple exit signs/emergency flood lights failed back up power testing.

All exit signs must be operational to identify a change in the direction of egress travel.

Correction: Verification received that all exit signs have been fixed.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

04/07/2024

Status: **Corrected**

Actual
Completion
Date:

03/26/2024

Laura Gloege

Provider Signature

03/07/2024

Date

Charles Schmidt

Inspector Signature

03/07/2024

Date