

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **St. Thomas More Preschool & After School Care Program**

City: **Brookings**

Provider Number: **011515539**

Inspector: **Charles Schmidt**

Date of Inspection: **09/30/2024**

Time of Inspection: **2:37 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?
67:42:17:39 NOTE: Outlet plug covers are not permitted.

<p>Corrections To Be Made:</p> <p>At time of inspection, not all areas used by program had self-closing or tamper resistant childproof electrical covers.</p> <p>All unused electrical outlets must have self-closing or tamper resistant childproof electrical covers.</p> <p>Correction: It was verified at time of program inspection that all electrical outlets are now self-closing in rooms used by program for child care purposes.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">10/31/2024</td> <td style="text-align: center;">10/21/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	10/31/2024	10/21/2024
Suggested Completion Date:	Actual Completion Date:				
10/31/2024	10/21/2024				

Marissa Kessler

Provider Signature

09/30/2024

Date

Charles Schmidt

Inspector Signature

09/30/2024

Date