

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Little Angels Day Care**

City: **Watertown**

Provider Number: **011515893**

Inspector: **Eric Anderson**

Date of Inspection: **04/03/2023**

Time of Inspection: **8:53 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

No exit sign on the north door.

Exit sign was hung at time of inspection.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

04/03/2023

Actual
Completion
Date:

04/03/2023

Status: **Corrected Immediately**

Angela Laframboise

Provider Signature

04/03/2023

Date

Eric Anderson

Inspector Signature

04/03/2023

Date