

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Immaculate Conception Kids  
On Target**

City: **Watertown**

Provider Number: **011515993**

Inspector: **Eric Anderson**

Date of Inspection: **03/05/2024**

Time of Inspection: **12:45 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?  
67:42:17:39 NOTE: Outlet plug covers are not permitted.

Corrections To Be Made:	Agency Action:	
<b>At the time of the inspection, some outlets in the licensed areas were not self-closing.</b>	<b>Compliance Plan</b>	
<b>All unused electrical outlets must have self-closing or tamper resistant childproof electrical covers.</b>	Suggested Completion Date:	Actual Completion Date:
<b>Correction: Verification received that all unused outlets have self-closing electrical covers.</b>	<b>03/26/2024</b>	<b>03/14/2024</b>
	Status: <b>Corrected</b>	

**Becca Briggs**

Provider Signature

**03/05/2024**

Date

**Eric Anderson**

Inspector Signature

**03/05/2024**

Date