

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Early Learning Center of Brookings**

City: **Brookings**

Provider Number: **011517222**

Inspector: **Charles Schmidt**

Date of Inspection: **04/24/2023**

Time of Inspection: **12:43 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

Corrections To Be Made:

**A crib that is not in use was placed in front of exit door, blocking the exit.**

**Correction: Crib was removed immediately at time of inspection to allow for proper exit.**

Agency Action:

### Compliance Plan

Suggested  
Completion  
Date:

**04/24/2023**

Actual  
Completion  
Date:

**04/24/2023**

Status: **Corrected Immediately**

## C. FOOD SERVICE

95. Are all utensils/equipment stored at least six inches above the floor in a clean, dry, protected location, and not placed under exposed sewer or water lines except for fire protection sprinkler lines?  
67:42:11:29

Corrections To Be Made:

**A box of cups were sitting directly on floor at time of inspection.,**

**Correction: Item was immediately removed from floor.**

Agency Action:

**Compliance Plan**

Suggested  
Completion  
Date:

Actual  
Completion  
Date:

**04/24/2023**

**04/24/2023**

Status: **Corrected Immediately**

**Barb Caulfield**

Provider Signature

**04/24/2023**

Date

**Charles Schmidt**

Inspector Signature

**04/24/2023**

Date