

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Sunnyside Daycare**

City: **Pierre**

Provider Number: **011517588**

Inspector: **Chad Wrightson**

Date of Inspection: **08/22/2023**

Time of Inspection: **4:03 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. Fire and Life Safety

5. In Licensed Programs caring for 21 or More Children - Is a fire alarm system inspected and serviced annually by a qualified service technician? 61:15:01:01

### Corrections To Be Made:

**At the time of the inspection the program's fire alarm system had not been inspected by a qualified service technician.**

**Licensed Programs caring for more than 21 or more children will have their fire alarm system inspected and serviced annually by a qualified service technician.**

**The program provided verification that their fire alarm system was serviced on 11/15/2023 by a qualified service technician.**

### Agency Action:

#### Compliance Plan

Suggested  
Completion  
Date:

**12/31/2023**

Actual  
Completion  
Date:

**11/22/2023**

Status: **Corrected**

**Katy Big Eagle**

Provider Signature

**08/22/2023**

Date

**Chad Wrightson**

Inspector Signature

**08/22/2023**

Date