

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Brookings School District - Medary**

City: **Brookings**

Provider Number: **011517629**

Inspector: **Charles Schmidt**

Date of Inspection: **07/30/2024**

Time of Inspection: **10:51 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

<p>Corrections To Be Made:</p> <p>Carbon monoxide detector not installed at time of the inspection.</p> <p>If there is a furnace or appliances utilizing fossil fuels such as propane, natural gas, etc., a carbon monoxide detector is required to be installed according to the manufacturer's directions.</p> <p>Correction: Verification received that a carbon monoxide detector has been installed according to manufacturer's directions.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/31/2024</td> <td style="text-align: center;">08/09/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/31/2024	08/09/2024
Suggested Completion Date:	Actual Completion Date:				
08/31/2024	08/09/2024				

Tanna

Provider Signature

07/30/2024

Date

Charles Schmidt

Inspector Signature

07/30/2024

Date