Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name:	**Brookings School District Preschool - Hillcrest**	City:	**Brookings**	Provider Number:	**011517630**
Inspector:	**Charles Schmidt**	Date of Inspection:	**07/30/2024**	Time of Inspection:	**9:44 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

Corrections To Be Made:

Carbon monoxide detector not installed at the time of inspection.

If there is a furnace or appliance that utilizes fossil fuels such as propane, natural gas, etc., a carbon monoxide detector must be installed.

Correction: Verification received that a carbon monoxide detector has been installed according to manufacturer's directions.

Agency Action:

Compliance Plan

Suggested Completion Date:	Actual Completion Date:
08/31/2024	**08/09/2024**

Status: **Corrected**

Tanna	**07/30/2024**	**Charles Schmidt**	**07/30/2024**
Provider Signature	Date	Inspector Signature	Date