

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Kingdom Kids Learning Center** City: **Huron** Provider Number: **014511974**
 Inspector: **Neal Cruse** Date of Inspection: **08/13/2024** Time of Inspection: **2:08 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?
 67:42:17:39 NOTE: Outlet plug covers are not permitted.

<p>Corrections To Be Made:</p> <p>Tamper proof outlets are not installed at time of inspection but are on order and will be installed.</p> <p>All unused electrical outlets must have self-closing or tamper resistant child proof covers.</p> <p>Verification received that the program installed self-closing outlet covers.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/25/2024</td> <td style="text-align: center;">10/02/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/25/2024	10/02/2024
Suggested Completion Date:	Actual Completion Date:				
08/25/2024	10/02/2024				

Kelly Wipf

 Provider Signature

08/13/2024

 Date

Neal Cruse

 Inspector Signature

08/13/2024

 Date