

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Little Tikes Daycare**

City: **Alexandria**

Provider Number: **014512098**

Inspector: **Carrie Lewis**

Date of Inspection: **10/13/2023**

Time of Inspection: **10:20 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

Corrections To Be Made:

There were no carbon monoxide detectors in the facility at the time of inspection.

The Provider installed two carbon monoxide detectors.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

10/27/2023

Actual
Completion
Date:

10/25/2023

Status: **Corrected**

Tori Tegethoff

Provider Signature

10/13/2023

Date

Carrie Lewis

Inspector Signature

10/13/2023

Date