

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Cougar Cubs Daycare**

City: **Bonesteel**

Provider Number: **014512466**

Inspector: **Renee Strong**

Date of Inspection: **09/25/2023**

Time of Inspection: **9:46 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## Miscellaneous Rule Violations

### 61:15:01 - Fire Safety Standards

Corrections To Be Made:	Agency Action:	
<b>Electrical outlets are not tamper-resistant or do not contain self-closing covers.</b>	<b>Compliance Plan</b>	
<b>For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant outlet.</b>	Suggested Completion Date:	Actual Completion Date:
<b>The program is currently obtaining bids for installing self-closing or tamper-resistant outlet covers. The program requests additional time to complete the project. The school age room will not be utilized for child care until the outlets have been replaced with tamper-resistant outlets.</b>	<b>04/30/2024</b>	<b>04/03/2024</b>
	Status: <b>Corrected</b>	

**Paula Kuhl**

Provider Signature

**09/25/2023**

Date

**Renee Strong**

Inspector Signature

**09/25/2023**

Date