

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Adventure Academy**

City: **Wagner**

Provider Number: **014512573**

Inspector: **Renee Strong**

Date of Inspection: **10/03/2024**

Time of Inspection: **2:02 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. Environmental Health

35. Is each bathroom provided with natural or mechanical ventilation? 67:42:17:33

Corrections To Be Made:

The bathroom between the infant and toddler rooms needs to have mechanical ventilation installed.

Verification was received that this issue was corrected.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

11/01/2024

Actual
Completion
Date:

10/14/2024

Status: **Corrected**

Bernie Koupal

Provider Signature

10/03/2024

Date

Renee Strong

Inspector Signature

10/03/2024

Date