

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Children's Care Corner Camp Inspiration**

City: **Howard**

Provider Number: **014512605**

Inspector: **Neal Cruse**

Date of Inspection: **05/30/2024**

Time of Inspection: **2:07 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?
67:42:17:39 NOTE: Outlet plug covers are not permitted.

Corrections To Be Made:

Outlets in gym are not tamper resistant.

Unused electrical outlets are required to have covers.

Self-closing covers were installed on the outlets.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

06/15/2024

Actual
Completion
Date:

06/18/2024

Status: **Corrected**

Rita Little Thunder

Provider Signature

05/30/2024

Date

Neal Cruse

Inspector Signature

05/30/2024

Date