

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Buzy Beez LLC**

City: **Wall**

Provider Number: **016597759**

Inspector: **Jeremy Rieger**

Date of Inspection: **05/06/2024**

Time of Inspection: **12:16 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

15. In Licensed Programs caring for 20 or Less Children - Is an interconnected smoke detection system operational and installed to meet coverage requirements? 61:15:06:08 NOTE: Detectors are to be located in all stairwells, corridors, sleeping rooms, and activity rooms .

Corrections To Be Made:

The smoke detector in the infant room is not working.

Provider will need to ensure the smoke detector is working properly by either replacing battery or replacing smoke detector.

Correction: Provider replaced the batteries in the smoke detector, everything is now working properly.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

05/10/2024

Status: **Corrected**

Actual
Completion
Date:

05/07/2024

Elyssa

Provider Signature

05/06/2024

Date

Jeremy Rieger

Inspector Signature

05/06/2024

Date