

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Our Little Treasures Daycare and Preschool**

City: **Rapid City**

Provider Number: **016597805**

Inspector: **Ann Marie Sailer**

Date of Inspection: **02/13/2024**

Time of Inspection: **12:23 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?
67:42:17:39 NOTE: Outlet plug covers are not permitted.

Corrections To Be Made:	Agency Action:	
Found two outlet plug covers during inspection.	Compliance Plan	
Outlet plug covers are not permitted. All unused electrical outlets must be self-closing or tamper resistant childproof electrical covers.	Suggested Completion Date:	Actual Completion Date:
Correction: Removed two outlet plug covers during inspection. Corrected immediately on site.	02/13/2024	02/13/2024
	Status: Corrected Immediately	

Julie Ekerson

Provider Signature

02/13/2024

Date

Ann Marie Sailer

Inspector Signature

02/13/2024

Date