

Family Day Care Inspection Compliance Plan

Provider's Name: **Abby Maidl**

City: **Rapid City**

Provider Number: **016597824**

Inspector: **Tina Uecker**

Date of Inspection: **06/11/2024**

Time of Inspection: **8:30 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. Health and Safety Features of the Home- Indoor Environmental Observations

54. Is the hot water temperature at hand washing sinks used by children in care maintained at 120 degrees F or lower? 67:42:17:33

Corrections To Be Made:	Agency Action:	
The hot water temperature measured at 122 degrees. Hot water temperature cannot exceed 120 degrees.	Compliance Plan	
Provider turned adjusted the hot water temperature gauge and sent OLA a statement saying that the water temperature did not exceed 120 degrees.	Suggested Completion Date: 06/30/2024	Actual Completion Date: 06/14/2024
	Status: Corrected	

Abby Maidl

Provider Signature

06/14/2024

Date

Tina Uecker

Inspector Signature

06/14/2024

Date