

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Skies the Limit Academy**

City: **Fort Meade**

Provider Number: **016597854**

Inspector: **Terra Robbins**

Date of Inspection: **04/14/2023**

Time of Inspection: **10:22 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

44. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?
67:42:11:09

Corrections To Be Made:

Hot water temperature found at 124 to 126F in building 75.

The hot water temperature should be maintained at 120F or less.

Correction: The water heater was adjusted to not exceed 120 degrees.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

05/05/2023

Actual
Completion
Date:

04/25/2023

Status: **Corrected**

Ariel Lewis

Provider Signature

04/14/2023

Date

Terra Robbins

Inspector Signature

04/14/2023

Date