

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **City Kids LLC**

City: **Rapid City**

Provider Number: **016598108**

Inspector: **Robert Weig**

Date of Inspection: **02/28/2024**

Time of Inspection: **9:06 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

<p>Corrections To Be Made:</p> <p>At the time of the inspection, a carbon monoxide detector was not installed at the program.</p> <p>A carbon monoxide detector must be installed.</p> <p>The program sent in a statement verifying that a carbon monoxide detector has been installed.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/14/2024</td> <td style="text-align: center;">03/18/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/14/2024	03/18/2024
Suggested Completion Date:	Actual Completion Date:				
03/14/2024	03/18/2024				

Kim Silbernagel

Provider Signature

02/28/2024

Date

Robert Weig

Inspector Signature

02/28/2024

Date