

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Challenging Minds**

City: **Summerset**

Provider Number: **016598599**

Inspector: **Jeremy Rieger**

Date of Inspection: **09/12/2022**

Time of Inspection: **3:45 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

18. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

Corrections To Be Made:

The fire extinguisher in the kitchen has a failed tag from 5/23/22 and has not been replaced. Fire extinguishers must be charged and operational.

***The program purchased a new fire extinguisher and sent verification to OLA.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

09/16/2022

Actual
Completion
Date:

09/30/2022

Status: **Corrected**

Stacy Phillips

Provider Signature

09/12/2022

Date

Jeremy Rieger

Inspector Signature

09/12/2022

Date