

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **PINE RIDGE LEARNING CENTER**

City: **Pine Ridge**

Provider Number: **016599296**

Inspector: **Meredith Schrier**

Date of Inspection: **08/13/2024**

Time of Inspection: **10:12 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

Corrections To Be Made:

Program did not have a carbon monoxide detector. A carbon monoxide detector must be installed.

A carbon monoxide detector was installed at the program.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

09/01/2024

Actual
Completion
Date:

08/27/2024

Status: **Corrected**

Tawnee Cottier

Provider Signature

08/13/2024

Date

Meredith Schrier

Inspector Signature

08/13/2024

Date