

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Campus Learning Center for Children**

City: **Sioux Falls**

Provider Number: **018026052**

Inspector: **Todd Lowe**

Date of Inspection: **03/02/2023**

Time of Inspection: **10:52 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p>The north exit light to be operational.</p> <p>*Correction: Batteries have been replaced in the light and it is now functional.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/09/2023</td> <td style="text-align: center;">03/28/2023</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/09/2023	03/28/2023
Suggested Completion Date:	Actual Completion Date:				
03/09/2023	03/28/2023				

C. FOOD SERVICE

72. If meals are catered by an outside, approved food management business, does the day care have a copy of a current Dept. of Health license for that food management business? 67:42:10:13 NOTE: Once meals are delivered, it is the licensed facility's responsibility to have the equipment and knowledge to properly store, heat, & serve the meals according to the food handling practices identified in this section.

Corrections To Be Made:

Meals are provided by Sodexo and a current copy of the food service license or most recent health inspection could not be found.

***Correction: copy of food service license received.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

Actual
Completion
Date:

03/09/2023

03/08/2023

Status: **Corrected**

Judy Knadel

Provider Signature

03/02/2023

Date

Todd Lowe

Inspector Signature

03/02/2023

Date