

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Good News Childrens Center**

City: **Sioux Falls**

Provider Number: **018038530**

Inspector: **Todd Lowe**

Date of Inspection: **01/24/2023**

Time of Inspection: **3:56 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

Corrections To Be Made:

The fellowship hall exit door had snow in front of it making opening the door improbable.

The provider will ensure that snow removal is completed in front of all exits.

Correction: The provider removed the snow immediately.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

01/25/2023

Actual
Completion
Date:

01/25/2023

Status: **Corrected Immediately**

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

Corrections To Be Made:

There was combustible material stored less than 2 feet below the ceiling in the storage room in classroom 7.

In storage rooms, combustible materials must be at least 2 feet below the ceiling or 18 inches below sprinklers head.

Correction: The provider cleaned out the storage room to ensure combustible materials are stored at least 24" below the ceiling.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

01/31/2023

Actual
Completion
Date:

01/31/2023

Status: **Corrected**

B. ENVIRONMENTAL HEALTH

33. Is there a hand-sink near the diaper changing area? 67:42:11:06.01

Corrections To Be Made:	Agency Action:	
The portable sink in the 1-year-old room was not operational.	Compliance Plan	
There must be an operational hand- sink near the diaper changing area.	Suggested Completion Date:	Actual Completion Date:
Correction: The provider fixed the hand sink to ensure it is operational.	01/25/2023	01/25/2023
	Status: Corrected	

C. FOOD SERVICE

74. Do employees wash hands after use of restroom, changing a diaper, working with soiled clothing/linens, and before handling food? 67:42:11:33

Corrections To Be Made:	Agency Action:	
The portable sink in the 1-year-old room was not operational so staff were unable to wash their hands after diaper changing.	Compliance Plan	
There must be an operational hand- sink near the diaper changing area.	Suggested Completion Date:	Actual Completion Date:
Correction: The provider fixed the hand sink to ensure staff can wash their hands after diaper changing.	01/25/2023	01/25/2023
	Status: Corrected	

Tammy Westergaard
Provider Signature

01/24/2023
Date

Todd Lowe
Inspector Signature

01/24/2023
Date