

Family Day Care Inspection Compliance Plan

Provider's Name: **KRISTINA PIESCHKE**

City: **Sioux Falls**

Provider Number: **018041898**

Inspector: **Todd Lowe**

Date of Inspection: **10/11/2022**

Time of Inspection: **11:42 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. Record Keeping/Fire Safety & Emergency Weather Drills

30. Does each child's record contain all required information? 67:42:16:13

Corrections To Be Made:

ED - Immunization Records

Agency Action:

Compliance Plan

Suggested
Completion
Date:

11/11/2022

Actual
Completion
Date:

10/18/2022

Status: **Corrected**

C. Health & Safety Features of the Home - Indoor Environmental Observations

69. Is the hot water temperature at hand washing sinks maintained at 120 degrees or lower?
67:42:03:11.05

Corrections To Be Made:

The main floor restroom water was too hot.

The hot water temperature at hand-washing sinks should be maintained at 120 degrees or lower.

Correction: Provider lowered the water temperature to ensure it is at 120 degrees or lower.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

10/15/2022

Actual
Completion
Date:

10/17/2022

Status: **Corrected**

76. For each level of the home used for the care of children, are there 2 unblocked exits, separate and remote from each other? 67:42:03:11.03 Note: Window wells or outside structures of building etc. cannot inhibit or prevent safe exiting.

Corrections To Be Made:

Items had been placed in front of exit door blocking the exit.

All exits need to remain unblocked at all times.

Correction: Provider corrected this immediately.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

10/11/2022

Actual
Completion
Date:

10/11/2022

Status: **Corrected Immediately**

Kristina Pieschke

Provider Signature

10/11/2022

Date

Todd Lowe

Inspector Signature

10/11/2022

Date