

# Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **B & G Club Explorer  
Elementary ASE**

City: **Sioux Falls**

Provider Number: **018042113**

Inspector: **Michael  
Czmowski**

Date of Inspection: **10/31/2022**

Time of Inspection: **4:55 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## B. ENVIRONMENTAL HEALTH

17. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p><b>Documentation for the annual heating and cooling system was not available during the inspection.</b></p> <p><b>The heating and cooling system must be maintained and inspected annually.</b></p> <p><b>Correction: Documentation for the current heating and cooling system inspection was submitted to OLA.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>12/01/2022</b></td> <td style="text-align: center;"><b>11/17/2022</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>12/01/2022</b>	<b>11/17/2022</b>
Suggested Completion Date:	Actual Completion Date:				
<b>12/01/2022</b>	<b>11/17/2022</b>				

**Molly Skadsen**

**10/31/2022**

Provider Signature

Date

**Michael Czmowski**

**10/31/2022**

Inspector Signature

Date