

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Central Preschool & Kindergarten**

City: **Sioux Falls**

Provider Number: **018042174**

Inspector: **Sarah Boese**

Date of Inspection: **04/05/2024**

Time of Inspection: **2:32 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

7. In Licensed Programs caring for 21 or More Children - If a fire sprinkler system is present, is it inspected and serviced annually by a qualified service technician? 61:15:01:01

<p>Corrections To Be Made:</p> <p>The last inspection of the sprinkler system documented was February of 2023.</p> <p>If a fire sprinkler system is present, it must be inspected and serviced annually by a qualified service technician.</p> <p>The fire sprinkler system was inspected and will be inspected annually.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">04/19/2024</td> <td style="text-align: center;">04/12/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	04/19/2024	04/12/2024
Suggested Completion Date:	Actual Completion Date:				
04/19/2024	04/12/2024				

17. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05; 61:15:06:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p>The exit signs above the emergency exit in the square preschool room, in the extended care fridge room, and in room 152A are not self-luminous and did not illuminate when tested.</p> <p>Exit signs must illuminate when tested or be self-luminous.</p> <p>The exit signs now illuminate.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">04/15/2024</td> <td style="text-align: center;">04/16/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	04/15/2024	04/16/2024
Suggested Completion Date:	Actual Completion Date:				
04/15/2024	04/16/2024				

Melissa Ludens

Provider Signature

04/05/2024

Date

Sarah Boese

Inspector Signature

04/05/2024

Date