

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Boys and Girls Club-Journey Elementary**

City: **Sioux Falls**

Provider Number: **018042343**

Inspector: **Sarah Boese**

Date of Inspection: **12/13/2024**

Time of Inspection: **2:53 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. Fire and Life Safety

17. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05; 61:15:06:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:	Agency Action:	
<b>Commons area exit sign on the Northeast side is not illuminated.</b>	<b>Compliance Plan</b>	
<b>Exit signs must be interior or exterior illuminated or self-luminous.</b>	Suggested Completion Date:	Actual Completion Date:
<b>Correction: The commons area exit sign was fixed to be illuminated.</b>	<b>12/23/2024</b>	<b>12/26/2024</b>
	Status: <b>Corrected</b>	

**Morgan Schumacher**

Provider Signature

**12/13/2024**

Date

**Sarah Boese**

Inspector Signature

**12/13/2024**

Date