

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Tiny Toes Adventure Center**

City: **Brookings**

Provider Number: **011517598**

Inspector: **Charles Schmidt**

Date of Inspection: **04/24/2023**

Time of Inspection: **10:53 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

15. Is electrical system being used properly? 61:15:01 NOTE: Check for overloads or frayed extension cords.

### Corrections To Be Made:

**Power strip in office must be plugged directly into wall outlet. Currently plugged into extension cord.**

**Correction: Verification received that power strip is now plugged directly into the wall.**

### Agency Action:

#### Compliance Plan

Suggested  
Completion  
Date:

**04/30/2023**

Actual  
Completion  
Date:

**05/31/2023**

Status: **Corrected**

## B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

### Corrections To Be Made:

**Verification of a current heating/cooling system inspection was not available at time of inspection.**

**Correction: Verification received that system was recently inspected.**

### Agency Action:

#### Compliance Plan

Suggested  
Completion  
Date:

**04/30/2023**

Actual  
Completion  
Date:

**06/13/2023**

Status: **Corrected**

**Madi Molengraaf**

Provider Signature

**04/24/2023**

Date

**Charles Schmidt**

Inspector Signature

**04/24/2023**

Date