

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Tiger Tots Preschool and Childcare**

City: **Harrisburg**

Provider Number: **018042435**

Inspector: **Sarah Boese**

Date of Inspection: **06/07/2024**

Time of Inspection: **3:13 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. Fire and Life Safety

5. In Licensed Programs caring for 21 or More Children - Is a fire alarm system inspected and serviced annually by a qualified service technician? 61:15:01:01

Corrections To Be Made:	Agency Action:	
<b>Documentation for the annual fire alarm inspection was not available at the time of the inspection.</b>	<b>Compliance Plan</b>	
<b>The Fire alarm system must be inspected and serviced annually by a qualified service technician.</b>	Suggested Completion Date:	Actual Completion Date:
<b>Correction: The provider submitted documentation verifying that the fire alarm was serviced and inspected by a certified technician within the past calendar year.</b>	<b>06/21/2024</b>	<b>06/20/2024</b>
	Status: <b>Corrected</b>	

17. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05; 61:15:06:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:	Agency Action:	
<b>The exit signs located on the main lobby back door (facing East) and the backdoor in the toddler hall (facing East) did not illuminate during testing.</b>	<b>Compliance Plan</b>	
<b>The exit signs must be illuminated both with and without electricity.</b>	Suggested Completion Date:	Actual Completion Date:
<b>Correction: The provider verified that the exit signs have been replaced.</b>	<b>06/21/2024</b>	<b>07/02/2024</b>
	Status: <b>Corrected</b>	

**Angela Nichols**

Provider Signature

**06/07/2024**

Date

**Sarah Boese**

Inspector Signature

**06/07/2024**

Date