

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Discovery Learning Center**

City: **Sioux Falls**

Provider Number: **018042494**

Inspector: **Todd Lowe**

Date of Inspection: **02/15/2024**

Time of Inspection: **10:40 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

18. Are exits and exit corridors maintained in a safe manner? 61:15:05:05; 61:15:06:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths maintained at 36 inches or more; exits cannot be obstructed.

Corrections To Be Made:

An exit door did not open with one motion.

Each level of a day care center where the occupant load exceeds ten must have at least two remote exits that meet the requirements set forth in chapter 10 of the International Building Code, 2015 edition. The two required exits must discharge directly to the outside and must swing in the direction of exit travel when the occupant load exceeds 50.

Correction: All exit doors open with one motion.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

02/16/2024

Actual
Completion
Date:

02/28/2024

Status: **Corrected**

B. Environmental Health

39. Is there a hand sink in the same room, or in an unobstructed adjacent room, to wash hands after each diaper change? 67:42:17:33

Corrections To Be Made:

The hand sink in the one year old classroom was not working.

Toilets and hand sinks must be kept clean and in good repair.

Correction: A basin was provided for providers and a work order was initiated at the time of inspection.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

02/15/2024

Actual
Completion
Date:

02/15/2024

Status: **Corrected Immediately**

58. Is the playground equipment installed according to the manufacturer ' s instructions and in good repair? 67:42:17:35

Corrections To Be Made:	Agency Action:	
The south playground had playground equipment that was not in good repair.	Compliance Plan	
Playground equipment must be installed according to the manufacturer's instructions and maintained in good repair.	Suggested Completion Date:	Actual Completion Date:
Correction: Playground equipment was repaired.	02/21/2024	02/28/2024
	Status: Corrected	

60. For a school age program, are all play areas which are near an area that is dangerous or life-threatening that could pose a risk of a serious injury to children enclosed with a fence that is at least 42 " high? 67:42:17:35 NOTE: This includes but is not limited to pools, water filled ditches, high traffic areas, etc.

Corrections To Be Made:	Agency Action:	
The Northeast entrance gate that leads through the playground is not in good repair and is an unreliable barrier.	Compliance Plan	
For a center program, a fence that measures at least four feet high is required around the center's outdoor play space.	Suggested Completion Date:	Actual Completion Date:
Correction: The Northeast entrance gate that leads through the playground was repaired.	02/29/2024	03/12/2024
	Status: Corrected	

Mel Mafi
Provider Signature

02/15/2024
Date

Todd Lowe
Inspector Signature

02/15/2024
Date