

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Snicklefritz Prep South**

City: **Harrisburg**

Provider Number: **018042503**

Inspector: **Sarah Boese**

Date of Inspection: **04/08/2024**

Time of Inspection: **1:26 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

21. Are portable fire extinguishers charged, operable, and inspected annually by a qualified service technician? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

Corrections To Be Made:	Agency Action:
There was not current documentation for an annual inspection available at the time of the inspection.	Compliance Plan
A qualified service technician must inspect a fire extinguisher on an annual basis.	Suggested Completion Date: 04/19/2024
A qualified service technician inspected the fire extinguishers, and the provider provided updated documentation.	Actual Completion Date: 04/15/2024
	Status: Corrected

Karli Dubro

Provider Signature

04/08/2024

Date

Sarah Boese

Inspector Signature

04/08/2024

Date