

# Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **Embe Freedom Elementary**      City: **Harrisburg**      Provider Number: **018042556**  
 Inspector: **Todd Lowe**      Date of Inspection: **09/12/2022**      Time of Inspection: **4:07 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

4. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p><b>Exit signs must be interior or exterior illuminated or self-luminous.</b></p> <p><b>The southwest door and northwest door emergency exit lights located in the gymnasium were not working.</b></p> <p><b>Exit lights are now operable.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>10/12/2022</b></td> <td style="text-align: center;"><b>10/17/2022</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>10/12/2022</b>	<b>10/17/2022</b>
Suggested Completion Date:	Actual Completion Date:				
<b>10/12/2022</b>	<b>10/17/2022</b>				

Jessica Rubenstein  
Provider Signature

09/12/2022  
Date

Todd Lowe  
Inspector Signature

09/12/2022  
Date