

Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **EmBe Harrisburg Liberty OST** City: **Harrisburg**

Provider Number: **018042619**

Inspector: **Todd Lowe** Date of Inspection: **03/21/2023**

Time of Inspection: **5:04 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

2. Are portable fire extinguishers charged and operable? 61:15:05:10

Corrections To Be Made:	Agency Action:	
A fire extinguisher located near the Mechanical Room in the commons area had an out-of-date tag indicating the last inspection was June of 2021.	Compliance Plan	
Fire extinguishers must be inspected annually.	Suggested Completion Date:	Actual Completion Date:
Correction: the program submitted the updated tag from July 2022.	03/28/2023	04/26/2023
	Status: Corrected	

C. FOOD SERVICE

32. Are food containers stored a minimum of 6 inches above floor, stored away from exposed and unprotected sewer lines and water lines (except automatic fire system sprinkler heads)? 67:42:11:18
NOTE: Food cannot be stored in toilet rooms, hallways or lobbies.

Corrections To Be Made:

Food items were discovered in milk crates and stored directly on the floor.

Food must be stored a minimum of 6 inches above the floor.

Correction: food is stored 6 inches above the floor.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

03/22/2023

Actual
Completion
Date:

03/24/2023

Status: **Corrected**

Aybree Pitman

Provider Signature

03/21/2023

Date

Todd Lowe

Inspector Signature

03/21/2023

Date