

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Bright Eyes Daycare**

City: **Sioux Falls**

Provider Number: **018042676**

Inspector: **Todd Lowe**

Date of Inspection: **05/21/2024**

Time of Inspection: **10:54 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

Corrections To Be Made:

**The program did not have a carbon monoxide detector installed.**

**A carbon monoxide detector must be installed according to the manufacturer's instructions.**

**Correction: The program installed a carbon monoxide detector.**

Agency Action:

### Compliance Plan

Suggested  
Completion  
Date:

Actual  
Completion  
Date:

**05/25/2024**

**05/21/2024**

Status: **Corrected**

**Nate Petersen**

Provider Signature

**05/21/2024**

Date

**Todd Lowe**

Inspector Signature

**05/21/2024**

Date