

Family Day Care Inspection Compliance Plan

Provider's Name: **Lydia Adcock**

City: **Sioux Falls**

Provider Number: **018042748**

Inspector: **Rita Trager**

Date of Inspection: **11/12/2024**

Time of Inspection: **9:09 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. Health and Safety Features of the Home- Indoor Environmental Observations

53. If a fuel burning appliance is present in the home, is there a carbon monoxide detector installed according to the manufacturer ' s directions? 67:42:17:37

Corrections To Be Made:	Agency Action:	
There is no carbon monoxide detector in the home.	Compliance Plan	
A carbon monoxide detector to be installed in the home and documentation provided to Office of Licensing and Accreditation.	Suggested Completion Date:	Actual Completion Date:
*Correction: a carbon monoxide detector has been purchased and installed in the home as required.	11/30/2024	11/13/2024
	Status: Corrected	

Lydia Adcock

Provider Signature

11/12/2024

Date

Rita Trager

Inspector Signature

11/12/2024

Date