

Family Day Care Inspection Compliance Plan

Provider's Name: **Cynthia Rust**

City: **Sioux Falls**

Provider Number: **018042776**

Inspector: **Sarah Boese**

Date of Inspection: **05/04/2023**

Time of Inspection: **9:39 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. Health & Safety Features of the Home - Indoor Environmental Observations

69. Is the hot water temperature at hand washing sinks maintained at 120 degrees or lower?
67:42:03:11.05

Corrections To Be Made:

At the time of the inspection, the hot water temperature measured at 125 degrees.

Correction: The hot water temperature was lowered to 120 degrees or below.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

05/04/2023

Actual
Completion
Date:

05/05/2023

Status: **Corrected**

Cynthia Rust

Provider Signature

05/04/2023

Date

Sarah Boese

Inspector Signature

05/04/2023

Date