

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Manda's Munchkins**

City: **Elk Point**

Provider Number: **018042795**

Inspector: **Stacy Wildermuth**

Date of Inspection: **01/27/2023**

Time of Inspection: **8:30 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

Corrections To Be Made:

Exit from the storage room to the outside play area is blocked with snow. Exits should be openable and maintained safe.

***Correction: Exit has been cleared of snow.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

01/27/2023

Actual
Completion
Date:

02/01/2023

Status: **Corrected**

B. ENVIRONMENTAL HEALTH

58. Are cleaning supplies kept inaccessible to children? 67:42:11:40

Corrections To Be Made:

Storage cabinet for cleaning supplies in the restroom was found unlocked during inspection. Cleaning supplies should be always kept inaccessible to children.

***Correction: Cabinet has been locked.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

01/27/2023

Actual
Completion
Date:

02/01/2023

Status: **Corrected**

Amanda Abraham

Provider Signature

01/27/2023

Date

Stacy Wildermuth

Inspector Signature

01/27/2023

Date