

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Kinder Academy**

City: **Sioux Falls**

Provider Number: **018042917**

Inspector: **Todd Lowe**

Date of Inspection: **01/23/2023**

Time of Inspection: **4:32 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

Exit light on the west exit of the multi-purpose room was not illuminated and did not illuminate when tested.

Exit signs must be self-luminous.

Correction: The provider fixed the exit light and the light now illuminates.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

02/01/2023

Actual
Completion
Date:

01/29/2023

Status: **Corrected**

Jennifer Schuette

Provider Signature

01/23/2023

Date

Todd Lowe

Inspector Signature

01/23/2023

Date