

Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - Non-School Location Compliance Plan

Provider's Name: **Snicklefritz South Kids Club** City: **Harrisburg** Provider Number: **018042942**
 Inspector: **Todd Lowe** Date of Inspection: **09/15/2022** Time of Inspection: **2:02 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

17. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. An extinguisher is located near food preparation area.

<p>Corrections To Be Made:</p> <p>Fire extinguishers could not be located at the time of the inspection.</p> <p>Portable fire extinguishers need to be charged and operable.</p> <p>Correction: 2A rate fire extinguishers were added to the facility.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">09/24/2022</td> <td style="text-align: center;">09/26/2022</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	09/24/2022	09/26/2022
Suggested Completion Date:	Actual Completion Date:				
09/24/2022	09/26/2022				

Amber Vandenberg
Provider Signature

09/15/2022
Date

Todd Lowe
Inspector Signature

09/15/2022
Date