

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **For the Love of Children**

City: **Sioux Falls**

Provider Number: **018042944**

Inspector: **Todd Lowe**

Date of Inspection: **01/24/2023**

Time of Inspection: **11:45 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

The emergency light in the crib room was not working at the time of the inspection.

Emergency lighting is required under the exit lighting and must be maintained.

Correction: the emergency light was fixed.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

02/03/2023

Actual
Completion
Date:

02/24/2023

Status: **Corrected**

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

Corrections To Be Made:

The exits in the infant room, 2-year-old room and kitchen were partially obstructed with classroom items and a mop pail.

Corridor and aisle widths of 36" must be maintained and exits cannot be obstructed at any time.

Corrected immediatley: the exit paths were cleared at the time of the inspection.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

01/24/2023

Actual
Completion
Date:

01/24/2023

Status: **Corrected Immediately**

Kayla Jorgensen

Provider Signature

01/24/2023

Date

Todd Lowe

Inspector Signature

01/24/2023

Date