

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **For the Love of Children**

City: **Sioux Falls**

Provider Number: **018042944**

Inspector: **Todd Lowe**

Date of Inspection: **02/13/2024**

Time of Inspection: **10:02 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

Corrections To Be Made:

The program did not have a carbon monoxide detector at the time of the inspection.

There must be a carbon monoxide detector installed according to the manufacturer's directions.

The program installed a carbon monoxide detector.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

Actual
Completion
Date:

02/24/2024

03/13/2024

Status: **Corrected**

Marsha Kirschman

Provider Signature

02/13/2024

Date

Todd Lowe

Inspector Signature

02/13/2024

Date