

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Canton Area Preschool & Childcare**

City: **Canton**

Provider Number: **018042945**

Inspector: **Michael Czmowski**

Date of Inspection: **10/17/2022**

Time of Inspection: **3:54 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

47. To prevent entrance of insects, are all outside openings protected by tight-fitting, self-closing doors, a closed window, screening, controlled air currents, or other means? Are they maintained in good repair?
67:42:11:36

Corrections To Be Made:

Rooms with window air conditioners have small spaces around units which prevent the area from being completely sealed.

All openings in wall need to be sealed effectively to control insects.

Correction: Provider replaced the seals in the room with window air conditioners to ensure a tight seal.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

11/17/2022

Actual
Completion
Date:

11/14/2022

Status: **Corrected**

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:

Heating and cooling system maintained and inspected annually.

Boiler inspection not completed within the past year.

Correction: the boiler system has been inspected.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

11/17/2022

Actual
Completion
Date:

10/31/2022

Status: **Corrected**

April Sigler

Provider Signature

10/17/2022

Date

Michael Czmowski

Inspector Signature

10/17/2022

Date