

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Truks-N-Trykes Playcare**

City: **Sioux Falls**

Provider Number: **018042996**

Inspector: **Patrick Waltman**

Date of Inspection: **07/15/2024**

Time of Inspection: **1:08 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

7. In Licensed Programs caring for 21 or More Children - If a fire sprinkler system is present, is it inspected and serviced annually by a qualified service technician? 61:15:01:01

Corrections To Be Made:

No record at time of inspection for the sprinkler system being inspected since January of 2023.

The fire sprinkler system must be inspected annually.

Correction: The program obtained record of the current sprinkler system inspection.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/30/2024

Actual
Completion
Date:

08/22/2024

Status: **Corrected**

20. Is electrical system being used properly? 61:15:01:01 NOTE: Check for overloads or frayed extension cords.

Corrections To Be Made:

Two surge protectors being used in conjunction with each other.

The electrical system must be used properly.

The program removed one of the surge protectors.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/30/2024

Actual
Completion
Date:

08/05/2024

Status: **Corrected**

Jacob Sievers

Provider Signature

07/15/2024

Date

Patrick Waltman

Inspector Signature

07/15/2024

Date