

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Creator's Kids**

City: **Sioux Falls**

Provider Number: **018043065**

Inspector: **Sarah Boese**

Date of Inspection: **05/04/2023**

Time of Inspection: **2:49 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

Corrections To Be Made:	Agency Action:	
<b>East exit was blocked with a child safety gate.</b>	<b>Compliance Plan</b>	
<b>Exits cannot be obstructed.</b>	Suggested Completion Date:	Actual Completion Date:
<b>The provider removed the gate blocking the exit.</b>	<b>06/01/2023</b>	<b>05/25/2023</b>
	Status: <b>Corrected</b>	

**Ryan Kruse**

Provider Signature

**05/04/2023**

Date

**Sarah Boese**

Inspector Signature

**05/04/2023**

Date