

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Truks-N-Trykes @ Golden Gateway**

City: **Sioux Falls**

Provider Number: **018043066**

Inspector: **Patrick Waltman**

Date of Inspection: **03/07/2024**

Time of Inspection: **1:56 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?
67:42:17:39 NOTE: Outlet plug covers are not permitted.

Corrections To Be Made:

One tamper-resistant outlet had an outlet cover over one of the sockets and, upon removal, it was observed there was an obstruction inside the ground port.

All unused electrical outlets must have self-closing or tamper resistant electrical covers and be maintained in good repair.

The program removed the obstruction so the outlet is in good repair.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

03/21/2024

Actual
Completion
Date:

03/14/2024

Status: **Corrected**

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

Corrections To Be Made:

A carbon monoxide detector was not installed at the time of the inspection.

A carbon monoxide detector must be installed according to the manufacturer's directions.

A carbon monoxide detector is installed.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

03/21/2024

Actual
Completion
Date:

03/14/2024

Status: **Corrected**

Jeniah Johnson

Provider Signature

03/07/2024

Date

Patrick Waltman

Inspector Signature

03/07/2024

Date