

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Apple Blossom Academy**

City: **Sioux Falls**

Provider Number: **018043068**

Inspector: **Patrick Waltman**

Date of Inspection: **03/20/2024**

Time of Inspection: **11:45 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?  
67:42:17:39 NOTE: Outlet plug covers are not permitted.

Corrections To Be Made:	Agency Action:	
<b>There are multiple rooms with broken twisting-type TR outlets that need to be replaced.</b>	<b>Compliance Plan</b>	
<b>All unused electrical outlets have self-closing or tamper-resistant, childproof electrical covers.</b>	Suggested Completion Date: <b>04/16/2024</b>	Actual Completion Date: <b>04/12/2024</b>
<b>The provider replaced the broken TR outlets.</b>	Status: <b>Corrected</b>	

**Lisa Carson**

Provider Signature

**03/20/2024**

Date

**Patrick Waltman**

Inspector Signature

**03/20/2024**

Date