

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **605 Prep**

City: **Sioux Falls**

Provider Number: **018043085**

Inspector: **Patrick Waltman**

Date of Inspection: **07/05/2022**

Time of Inspection: **12:03 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

1. Is there a written emergency evacuation plan? Note: This may be found in the Emergency Preparedness and Response Plan.

Corrections To Be Made:	Agency Action:	
<b>The emergency preparedness and response plan were not developed at the time of the inspection.</b>	<b>Compliance Plan</b>	
<b>The program must develop an emergency preparedness and response plan and ensure staff are aware of the emergency procedures.</b>	Suggested Completion Date:	Actual Completion Date:
<b>Correction: The program submitted an emergency preparedness and response plan to Child Care Licensing.</b>	<b>06/08/2022</b>	<b>06/07/2022</b>
	Status: <b>Corrected</b>	

## B. ENVIRONMENTAL HEALTH

65. Is there a fenced outdoor play area? Does the fenced area appear to allow for 50 square feet per child during each scheduled recess time? 67:42:11:02

Corrections To Be Made:

**The outdoor play area was not fenced in at the time of the inspection. There is an electrical box in the playground that must be inaccessible to children.**

**The outdoor play area must be fenced in and maintained in a safe manner.**

**The program has a temporary fence around the playground until the permanent fence can be installed. The fence meets the intent of the regulation as it is chain link, and it is 4 feet high.**

**A wooden cover has been built around the electric box to ensure children don't have access to it.**

Agency Action:

**Compliance Plan**

Suggested  
Completion  
Date:

Actual  
Completion  
Date:

**05/08/2022**

**07/19/2022**

Status: **Corrected**

**Jessica Snyder**

Provider Signature

**07/05/2022**

Date

**Patrick Waltman**

Inspector Signature

**07/05/2022**

Date