

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **School of Early Education -  
Brandon**

City: **Brandon**

Provider Number: **018043091**

Inspector: **Patrick Waltman**

Date of Inspection: **01/30/2024**

Time of Inspection: **10:29 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## B. Environmental Health

33. Are toilets and hand sinks kept clean and in good repair? 67:42:17:33

|  |  |                            |                         |                   |                   |
|--|--|----------------------------|-------------------------|-------------------|-------------------|
| <p>Corrections To Be Made:</p> <p><b>There was a hand sink that was not secured to the sink countertop.</b></p> <p><b>Toilets and hand sinks must be kept clean and in good repair.</b></p> <p><b>Correction: The hand sink was secured to the countertop.</b></p> | <p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%; border: none;">Suggested Completion Date:</td> <td style="width: 50%; border: none;">Actual Completion Date:</td> </tr> <tr> <td style="border: none;"><b>02/15/2024</b></td> <td style="border: none;"><b>02/08/2024</b></td> </tr> </table> <p>Status: <b>Corrected</b></p> | Suggested Completion Date: | Actual Completion Date: | <b>02/15/2024</b> | <b>02/08/2024</b> |
| Suggested Completion Date:   | Actual Completion Date:  |                            |                         |                   |                   |
| <b>02/15/2024</b>  | <b>02/08/2024</b>  |                            |                         |                   |                   |

34. Is the hot water temperature at hand washing sinks used by children maintained at 120 degrees F or lower? 67:42:17:33

|  |  |                            |                         |                   |                   |
|--|--|----------------------------|-------------------------|-------------------|-------------------|
| <p>Corrections To Be Made:</p> <p><b>The hot water temperature at hand washing sinks used by children in care exceeded 120 degrees F.</b></p> <p><b>Hot water temperature at hand washing sinks used by children in care may not exceed one hundred twenty degrees Fahrenheit.</b></p> <p><b>Correction: The hot water temperature at hand washing sinks used by children in care was turned down to ensure the water temperature does not exceed 120 degrees.</b></p> | <p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%; border: none;">Suggested Completion Date:</td> <td style="width: 50%; border: none;">Actual Completion Date:</td> </tr> <tr> <td style="border: none;"><b>02/15/2024</b></td> <td style="border: none;"><b>01/31/2024</b></td> </tr> </table> <p>Status: <b>Corrected</b></p> | Suggested Completion Date: | Actual Completion Date: | <b>02/15/2024</b> | <b>01/31/2024</b> |
| Suggested Completion Date:   | Actual Completion Date:  |                            |                         |                   |                   |
| <b>02/15/2024</b>  | <b>01/31/2024</b>  |                            |                         |                   |                   |

**Heather Groos**

**01/30/2024**

**Patrick Waltman**

**01/30/2024**

Provider Signature

Date

Inspector Signature

Date