

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Little Wings Preschool**

City: **Sioux Falls**

Provider Number: **018043096**

Inspector: **Todd Lowe**

Date of Inspection: **08/15/2022**

Time of Inspection: **3:46 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

Noted that there was no exit sign installed over the east door(main entrance)

The exit signs have been installed.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

08/25/2022

Status: **Corrected**

Actual
Completion
Date:

08/19/2022

B. ENVIRONMENTAL HEALTH

41. Is each bathroom provided with natural or mechanical ventilation? 67:42:11:06

Corrections To Be Made:

The bathrooms in the Blue and Extended rooms did not have mechanical ventilation and had no access to natural ventilation.

The fans where connected and installed.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

08/25/2022

Status: **Corrected**

Actual
Completion
Date:

08/22/2022

Mel WehrKamp

Provider Signature

08/15/2022

Date

Todd Lowe

Inspector Signature

08/15/2022

Date