

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Em's Eastside Explorers**

City: **Parker**

Provider Number: **018043112**

Inspector: **Sarah Boese**

Date of Inspection: **06/27/2023**

Time of Inspection: **2:00 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Miscellaneous Rule Violations

67:42:03:21 - Other hazardous conditions.

Corrections To Be Made:

**Air conditioning units in the outside play area are accessible to children.
Fan guards are not small enough to prevent access on the top and slots
on the side also allow for children access.**

Fencing was placed around the units to prevent access by children.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/18/2023

Actual
Completion
Date:

08/24/2023

Status: **Corrected**

Emily Korthals

Provider Signature

06/27/2023

Date

Sarah Boese

Inspector Signature

06/27/2023

Date