

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Em's Eastside Explorers**

City: **Parker**

Provider Number: **018043112**

Inspector: **Renee Strong**

Date of Inspection: **06/25/2024**

Time of Inspection: **10:27 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

5. In Licensed Programs caring for 21 or More Children - Is a fire alarm system inspected and serviced annually by a qualified service technician? 61:15:01:01

Corrections To Be Made:

No documentation of a fire alarm inspection since Dec. 2022 was available.

The fire alarm system needs to be inspected yearly.

Verification of a current inspection was received.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/01/2024

Actual
Completion
Date:

07/03/2024

Status: **Corrected**

Emily Korthals

Provider Signature

06/25/2024

Date

Renee Strong

Inspector Signature

06/25/2024

Date